



County of Riverside  
DEPARTMENT OF ENVIRONMENTAL HEALTH  
[www.rivcoeh.org](http://www.rivcoeh.org)

---

**NOTICE OF VIOLATION FOR FAILING TO REPORT  
BACTERIOLOGICAL RESULTS**

**Date:** 4/30/2020

**To:** WEBER VALLEY HEIGHTS ASSOCIATI  
44135 Perryman Ln  
Hemet, CA 92544

**Re:** Weber Valley Heights Assoc  
44350 Benton RD  
Hemet, CA 92544-9783

The Department of Environmental Health, Water Resources Program, has not received the results of the required quarterly total and fecal coliform bacteriological tests from your water system. These results must be received in this Department by the tenth of the month following the sampling.

This water system is now in violation of California law for failing to perform and submit the sample results as specified in the California Code of Regulations Title 22, section 64212.


You must insure that the required bacteriological samples have been taken and the results reported to this office on a quarterly basis. The testing must be performed by a person familiar with the proper procedures in sampling, and use of a State certified laboratory for the testing is required. If you have a copy of these bacteriological test results, please forward them to the appropriate office listed below.

Your prompt cooperation in this matter is expected to provide adequate protection to your water system and its users. Failure to bring your water system into compliance may lead to legal action.

If you have any questions regarding this Notice, do not hesitate to contact the Indio office at (760) 863-7570 or the Riverside office at (951) 955-8980 and request to speak with staff from the Water Resources Program.

6-2-2020 Entered.  
DC

**Clinical Laboratory of San Bernardino, Inc.**  
Celebrating 50 Years of Analytical Service 1967-2017



Weber Valley Heights 44350 Benton Rd. Hemet CA, 92544	Project: Routine	Work Order: 20D1472
	Sub Project:	Received: 04/17/20 10:20
	Project Manager: Water Quality Supervisor	Reported: 04/23/20

Well 1 - Frank's Residence      20D1472-01 (Water)      Sample Date: 04/17/20 8:30      Sampler: Debbi St. Pierre

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
<b>Microbiology Analyses</b>									
Total Coliform	SM 9223	A			P/A	04/17/20	04/18/20	2016171	
E. Coli	SM 9223	A			P/A	04/17/20	04/18/20	2016171	

Well 2 - Faucet at Tank      20D1472-02 (Water)      Sample Date: 04/17/20 8:45      Sampler: Debbi St. Pierre


Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
<b>Microbiology Analyses</b>									
Total Coliform	SM 9223	A			P/A	04/17/20	04/18/20	2016171	
E. Coli	SM 9223	A			P/A	04/17/20	04/18/20	2016171	

ND      Analyte NOT DETECTED at or above the reporting limit

Nathaniel Fresquez For Leticia Bernstein  
Project Manager

# Clinical Laboratory of San Bernardino, Inc.

Celebrating 50 Years of Analytical Service 1967-2017



Weber Valley Heights 44350 Benton Rd. Hemet CA, 92544	Project: Routine	Work Order: 20G1747
	Sub Project:	Received: 07/20/20 09:59
	Project Manager: Water Quality Supervisor	Reported: 07/23/20

Well 1 - Frank Residence      20G1747-01 (Water)      Sample Date: 07/20/20 8:15      Sampler: Debbi St. Pierre

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
<b>Microbiology Analyses</b>									
Total Coliform	SM 9223	A			P/A	07/20/20	07/21/20	2030065	
E. Coli	SM 9223	A			P/A	07/20/20	07/21/20	2030065	

Well 2 - Faucet at Tank      20G1747-02 (Water)      Sample Date: 07/20/20 8:20      Sampler: Debbi St. Pierre

Analyte	Method	Result	Rep. Limit	MCL	Units	Prepared	Analyzed	Batch	Qualifier
<b>Microbiology Analyses</b>									
Total Coliform	SM 9223	A			P/A	07/20/20	07/21/20	2030065	
E. Coli	SM 9223	A			P/A	07/20/20	07/21/20	2030065	

ND Analyte NOT DETECTED at or above the reporting limit

Nathaniel Fresquez For Leticia Bernstein  
Project Manager

Post Office Box 329 San Bernardino, CA 92402 (909) 825-7693 Fax (909) 825-7696 ELAP Number 1088



