



**E.S.BABCOCK**&Sons,Inc.  
 Environmental Laboratories *est. 1906*

Client Name:Weber Valley Heights Association  
 Contact:Debbi St Pierre  
 Address:44350 Benton Rd.  
 Hemet, CA 92544

Analytical Report: Page 1 of 3  
 Project Name: Weber Valley DW-CCs  
 Project Number: No Project

**Work Order Number: B2G1578**

Report Date:20-Jul-2012

Received on Ice (Y/N): Yes Temp: 7°C

Attached is the analytical report for the sample(s) received for your project. Below is a list of the individual sample descriptions with the corresponding laboratory number(s). Also, enclosed is a copy of the Chain of Custody document (if received with your sample(s)). Please note any unused portion of the sample(s) may be responsibly discarded after 30 days from the above report date, unless you have requested otherwise.

Thank you for the opportunity to serve your analytical needs. If you have any questions or concerns regarding this report please contact our client service department.

**Sample Identification**

<u>Lab Sample #</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Sampled</u>	<u>By</u>	<u>Date Submitted</u>	<u>By</u>
B2G1578-01	Well #1 ---ROUTINE--- 001	Water	07/16/12 07:15	Robert Franko	07/16/12 10:00	Robert Franko
B2G1578-02	Well #2 ---ROUTINE--- 002	Water	07/16/12 07:30	Robert Franko	07/16/12 10:00	Robert Franko



**E.S.BABCOCK**&Sons,Inc.  
Environmental Laboratories *est. 1906*

Client Name:Weber Valley Heights Association  
Contact:Debbi St Pierre  
Address:44350 Benton Rd.  
Hemet, CA 92544

Analytical Report: Page 2 of 3  
Project Name: Weber Valley DW-CCs  
Project Number: No Project

**Work Order Number: B2G1578**

Report Date:20-Jul-2012

Received on Ice (Y/N): Yes Temp: 7°C

	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b>B2G1578-01</b> <i>Sampled: 07/16/12 07:15</i>							
Well #1001							
Heterotrophic Plate Count	>5700	1.0	CFU/mL	SM 9215B	07/16/12 13:15	dpk	
Total Coliform	Absent	1.1	----	SM 9223B	07/16/12 13:15	dpk	
E. coli	Absent	1.1	----	SM 9223B	07/16/12 13:15	dpk	

<b>B2G1578-02</b> <i>Sampled: 07/16/12 07:30</i>							
Well #2002							
Heterotrophic Plate Count	110	1.0	CFU/mL	SM 9215B	07/16/12 13:15	dpk	
Total Coliform	**PRESENT**	1.1	----	SM 9223B	07/16/12 13:15	dpk	B-01
E. coli	Absent	1.1	----	SM 9223B	07/16/12 13:15	dpk	



E.S.BABCOCK&Sons,Inc.
Environmental Laboratories est. 1906

Client Name:Weber Valley Heights Association
Contact:Debbi St Pierre
Address:44350 Benton Rd.
Hemet, CA 92544

Analytical Report: Page 3 of 3
Project Name: Weber Valley DW-CCs
Project Number: No Project

Work Order Number: B2G1578

Report Date:20-Jul-2012

Received on Ice (Y/N): Yes Temp: 7°C

Notes and Definitions

B-01 Bacteriological result notification provided to Debbie St Pierre on 7/17/12.

- ND: Analyte NOT DETECTED at or above the Method Detection Limit (if MDL is reported), otherwise at or above the Reportable Detection Limit (RDL)
NR: Not Reported
RDL: Reportable Detection Limit
MDL: Method Detection Limit
\*/'': NELAP does not offer accreditation for this analyte/method/matrix combination

Approval

Enclosed are the analytical results for the submitted sample(s). Babcock Laboratories certify the data presented as part of this report meet the minimum quality standards in the referenced analytical methods. Any exceptions have been noted. Babcock Laboratories and its officers and employees assume no responsibility and make no warranty, express or implied, for uses or interpretations made by any recipients, intended or unintended, of this report.

Handwritten signature of Lauren Tyner

Lauren Tyner, Project Manager

cc: RCHD

e-Tab\_Summary.rpt



E.S.BABCOCK & Sons, Inc. Environmental Laboratories est. 1906

Client Name: Weber Valley Heights Association
Contact: Debbi St Pierre
Address: 44350 Benton Rd. Hemet, CA 92544

Analytical Report: Page 1 of 1
Project Name: Weber Valley DW-CCs
Project Number: No Project

Work Order Number: B2G1578

Report Date: 20-Jul-2012

Received on Ice (Y/N): Yes Temp: 7°C

E.S. Babcock & Sons, Inc.
6100 Quail Valley Ct., Riverside, CA 92507
(951) 653-3351

Project Reference Lab No. B2G1578 AM

Sample Receipt Form

Client: Weber Valley Heights JUL 15 2012

Submitted By: Robert

Date: 7/16/12

Time: 1200

PAID

\$ 80

Per CK #1262

Sample Condition

Number of Containers: 2

Temperature: 7 °C

- Were Samples Submitted on Ice? No Yes
Were Samples Received Intact? No Yes
Were Samples in Proper Containers? No Yes
Were Sample Custody Seals Intact? No Yes N/A
Chain of Custody Received? No Yes
Submitted within Reg. Holding Times? No Yes
Is there Sufficient Volume? No Yes

Comments: Well #1 7/16/12 @ 7:15
Well #2 7/16/12 @ 7:30
(Routine)

By Robert Franko

Sample(s) Received By: [Signature]

DA HPC

Problem Contact Information: Person Contacted: Date/Init.:

Permission to Continue? Yes No \*On wet ice Dagg / in Ziplock